

## Republic of the Philippines

## **CAVITE STATE UNIVERSITY**

Don Severino de las Alas Campus

Indang, Cavite (046) 862-0852 www.cvsu.edu.ph

## **SUPPLEMENTAL / BID BULLETIN - 1**

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents. Please take note of the changes/adjustments for the project, CONSTRUCTION OF FOOD STALL INCLUDING THE IMPROVEMENT OF CANTEEN with an ABC of (₱ 1,218,829.71):

- Site inspection is a must.
- 2. There are existing structures.
- 3. On masonry and tile works:
  - a. Supply and installation of colored ceramic tiles  $0.40 \, \text{m} \times 0.40 \, \text{m}$  for the whole floor area of food stall including the existing.
  - b. Supply and installation of colored ceramic tiles 0.40 m x 0.40 m for the new concrete counters.
  - c. Use CHB 4" reinforced with 10 mm diameter deformed bar spaced @ 0.60 m bothways for the concrete counters and enclosing wall of the food stall.
- 4. This bid bulletin does not cancel the information given in the scope of work of the Bill of Quantities but adds clarification to it. Please attach this added information/bid bulletin to the BOQ and be included in the financial envelop.
- The Construction and Safety Health Program of the Contractor to be submitted in this bidding procedure must be certified by its President/Owner. DOLE approved CSHP may be required upon post qualification.
- All projects to be undertaken by a contractor of the university should have its own electrical and
  resident site engineers. In cases of multiple projects, an electrical engineer may supervise all
  projects awarded to the said contractor.

For guidance and information of all concerned.

Prepared by:

MICHELLE A. SANTOS
BAC Secretary

Approved:

POLINGA, Phi

, Infrastructure Projects