



CAVITE STATE UNIVERSITY
Don Severino de las Alas Campus

Indang, Cavite, Philippines

☎ (046) 415-0010 / 📠 (046) 4150-0013 loc 203

www.cvsu.edu.ph

REQUEST FOR QUOTATION

Improvement of Maragondon Campus (Improvement of Electrical Service System)

1. The Cavite State University (CvSU) invites interested firms/suppliers to submit quotation for the project "Improvement of Maragondon Campus (Improvement of Electrical Service System)" with an Approved Budget for the Contract (ABC) of Three Hundred Fifty-Four Thousand Two Hundred Forty-Six Pesos and 5/100 Only (PhP 354,246.05). Quotation received in excess of the ABC shall be automatically rejected at the opening.

| Item No. | Quantity | Unit | Description | Unit Cost | Total Cost |
|---------------------|----------|------|--|-----------|-------------------|
| 1. | | | Improvement of Maragondon Campus (Improvement of Electrical Service System) <ul style="list-style-type: none">• Earthworks• Concrete Works• Electrical Works | | 354,246.05 |
| TOTAL AMOUNT | | | | | 354,246.05 |

2. The quotation must be submitted to the Supply Office through mail, fax or email at the contact details listed below on or before 5:00 PM of March 17, 2020.

Address : Supply Office, Administration Building
Cavite State University
Indang, Cavite
E-mail : supplyoffice@cvsu.edu.ph
Telefax : (046) 862-0852

3. The CvSU reserves the right to reject any or all quotations and/or proposals and waive any formalities/informalities therein and to accept such bids it may consider as most advantageous to the agency and to the government. CvSU neither assumes any obligation for whatsoever losses that may be incurred in the preparation of bids, nor does it guarantee that an award will be made.


PRECIOSA G. ERAÑA
BAC Secretary, Goods and Services



Republic of the Philippines
CAVITE STATE UNIVERSITY
 Don Severino delas Alas Campus
 Indang, Cavite

BILL OF QUANTITIES

| NAME OF PROJECT: IMPROVEMENT OF MARAGONDON CAMPUS (IMPROVEMENT OF ELECTRICAL SERVICE SYSTEM) ABC: ₱ 354,246.05 COLLEGE/UNIT/CAMPUS: CvSU MARAGONDON CAMPUS | | | | Bill of Quantities | |
|--|---|-------------------------|----------|---------------------------|----------------|
| Item No. | Description | Unit | Quantity | Unit Price (Pesos) | Amount (Pesos) |
| I | EARTHWORKS (Pesos _____ _____ and _____ centavos) | | | | |
| II | CONCRETE WORKS (Pesos _____ _____ and _____ centavos) | | | | |
| III | ELECTRICAL WORKS (Pesos _____ _____ and _____ centavos) | | | | |
| GRAND TOTAL | | | | | _____ |
| Write grand total in words | | _____ _____ _____ | | | |

Submitted by: _____ Date: _____

Name of Bidder/Bidder's Representative: _____

Position: _____

Construction Company/Contractor: _____

**A. IMPROVEMENT OF MARAGONDON CAMPUS
(IMPROVEMENT OF ELECTRICAL SERVICE SYSTEM)**

1. There is an existing structure. Site inspection is a must to verify site condition.
2. The project should be finished in 25 calendar days.

B. TECHNICAL DESCRIPTION

I. Earthworks

1. Excavation/backfilling/clearing
 - a. Excavation for column footing of electrical post.

II. Concrete Works

1. Construction of service entrance post
 - a. Concrete works include column and footing of electrical post.
 - b. Concrete mix should be in 1:2:4.
 - c. Concrete works should be plastered plain cement.
 - d. Deformed bar to be used shall be grade 33. See plan for sizes of bars to be used.

III. Electrical Works

1. Installation of feeder line and secondary post including all its accessories.
 - a. Installation of MDP and LLP and all other panel boards on the plan and their circuit breakers.
 - b. Bolt-on type Nema Standard should be used. Tap to the source including testing.
2. Installation of wiring/conductors and PVC conduits/junction box/utility box from main/sub-main panel boards to convenience outlet.
 - a. THWN stranded wire, phelp dodge or approved equal.
 - b. PVC conduit orange pipe with sizes as indicated on the plan.
 - c. Utility and junction boxes should be PVC & deep type.
3. Installation of electrical fixtures/switches/outlets and other electrical devices.
 - a. Convenience outlet (Bticino, National or approved equal) 6 sets.
 - b. Floor outlets (brass with cover) 16 sets.
4. Consult plan and inspectors for details and extent of work.

- IV. See plans for details and extent of work. The silence of specification, plans, special provision and supplementary specifications as to any detail, or the apparent omission therein of a detailed description or definition of the quality of materials and workmanship shall be regarded to mean that only materials and workmanship of first class quality are to be used or employed.**