



Republic of the Philippines
CAVITE STATE UNIVERSITY
Don Severino de las Alas Campus
Indang, Cavite
www.cvsu.edu.ph

BIDS AND AWARDS COMMITTEE
(INFRASTRUCTURE PROJECTS)

SUPPLEMENTAL / BID BULLETIN NO. 3

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents. Please take note of the changes/adjustments for the project, **Improvement of University Data Center (CvSU-BAC-INFRA-22-004)** with an **ABC** of **₱ 1,273,952.63**:

1. Site inspection is a must.
2. On miscellaneous works:
 - a. Framing and posts of generator housing should be 1 1/2" GI pipe S-40.
 - The gates are the front portion of the housing as shown in the front elevation. Provide heavy duty hinges 4" (3 pcs/door) and fabricated safety hasp using 1/4" x 1" flat bar and solid 12 mm. dia. bar.
3. On electrical works:
 - a. Supply and installation of panel boards complete with circuit breakers.
 - Remove & replace the existing MDP (see BOQ & plan)
 - LP for computer data center, 14 branches (see BOQ & plan)
 - Main 125AT, 300AF, 230V enclosed with box
 - b. Supply and installation of all lighting and power conduits, conductors, switches, outlets, ACU outlets, PVC junction and utility boxes for connection to ATS and generator for continuity of power supply at all times.
 - c. Supply and installation of Automatic Transfer Switch (ATS) instead of MTS.
 - d. Tapping to the source, testing and commissioning are included.
4. This bid bulletin does not cancel the information given in the scope of work of the issued Bill of Quantities but adds clarification to it. Please attach this added information/bid bulletin to the BOQ and include in the financial envelop.
5. All projects to be undertaken by a contractor of the university should have its own resident site engineer. Also, it is required that an electrical engineer or a master electrician be part of a contractors team to supervise all electrical works.

General notes:

1. In the event that there are discrepancies between the plans and scope of works, the scope of works shall prevail.
2. For the Key Personnel, specifically Foreman, Skilled Workers and Laborer, a certification that the said personnel are workers of the company should be submitted. (Signed by the Company President/Owner)
3. Packaging of Bids

Documents to be submitted should be arranged accordingly based on the Checklist of Bidding Requirements *preferably with corresponding tabs*.

The documents to be submitted must be secured in a sealed envelope marked "TECHNICAL COMPONENT (first envelope)" and "FINANCIAL COMPONENT (second envelope)" and must be contained in one sealed envelope marked "ORIGINAL COPY". The FIRST ENVELOPE and SECOND ENVELOPE should each have two duplicate copies. These duplicate copies shall also be packaged in another envelope marked "COPY 1" for the first duplicate copy while "COPY 2" for the second duplicate copy. The ORIGINAL COPY, COPY 1, and COPY 2 sealed envelopes must be packaged altogether in one mother envelope.

For guidance and information of all concerned.


Prepared by:


EFREN R. ROCILLO
TWG Chair



CENE M. BAGO
TWG Member


LARRY E. ROCELA
TWG Member


RONALD P. PEÑA
TWG Member


ELPIDIO N. RODEROS, JR.
TWG Member

Approved by:


MA. AGNES P. NUESTRO, PhD
Chair, BAC for Infrastructure Projects

Received by the Bidder : _____
Date : _____