



Republic of the Philippines
CAVITE STATE UNIVERSITY
Don Severino de las Alas Campus
Indang, Cavite
www.cvsu.edu.ph

BIDS AND AWARDS COMMITTEE
(INFRASTRUCTURE PROJECTS)

SUPPLEMENTAL / BID BULLETIN NO. 2

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents. Please take note of the changes/adjustments for the project, **Construction of Four-Storey Dormitory Phase 1 (CvSU-BAC-INFRA-22-010)** with an **ABC of ₱ 10,000,000.00**:

1. Site inspection is a must.
**Site temporary enclosure may be sack or any suitable materials that may enclose the workplace.
2. On earthworks:
 - a. All clearing works including cutting of trees is included but permits shall be processed by the university.
 - b. Provide soil poisoning by using environment friendly solution.
3. On concrete and masonry/tile works:
 - a. Lintel beams shall be provided above all openings of doors and windows: provide 0.15m x 0.20m beam reinforced with 2- 12mm Ø deformed bars tied with stirrups spaced at 0.15 meters on center.
 - b. Ready mixed concrete is preferred.
 - b.1. A concrete strength of 3500 psi is to be used.
 - b.2. Fabrication and testing of concrete samples shall be done by the contractor. Sample test results shall be attached to the billing.
 - c. Slab on fill is 4" thick with 10 mm Ø deformed bar spaced at 0.40 meters on center bothways. Compaction of soil filling to establish elevations is a must.
 - d. Dowel bars should be provided in a minimum height and length of one meter vertically for the columns and horizontally for the beam and slab beyond the poured concrete.
Take note that the concrete for beam and slab should extend at 1/3 of span of Grids 5 -6.
4. On miscellaneous works:
 - a. Supply and installation of 5 units W3 and 2 units W1.
5. On plumbing works:
 - a. Supply and installation of all sewer and water supply line at the specified grids including its fixtures to make the ground floor functional.
 - There should be 11 sets heavy duty shower head with valve complete with faucet for all cubicles of shower rooms.
 - There should be 6 sets tank type water closets along with 6 units hand held spray. Each cubicle of CR should also be installed with HD faucet.
 - There should be 5 units counter top type lavatories complete with heavy duty accessories including wall faucet.
 - There should be 2 more units of HD faucet for slop sinks.

Note: All fixtures must be colored complete with heavy accessories (American Std., HCG or its approved equal.)
 - b. Floor drains should use 3" Ø PVC orange pipes with brass drain fixture (12 units).
 - c. Provide gate valves and water meter (see plan for location).
 - d. Tap to the nearest water source for water supply while to the nearest disposal area for sewer line.
 - e. Construction of 4 units catch basin along Grid 1-2.
 - f. Construction of one unit septic tank.
6. On electrical works:
 - a. There are additional plans to clarify the extent of electrical works Grid 1-5 / A-D'.
 - Instead of MDP, supply and install 2 sets of weatherproof Panel Boards to be enclosed by a stainless false cabinet with padlock (see plan).

- conductors, wiring, convenience outlets, switches and special outlets for ACU and emergency light must be supplied and installed.
 - Provide electrical roughing-in to all ceiling fans.
- b. Supply and installation of electrical lighting fixtures.
- 20 sets 2-40W fluorescent fixtures troffer type with LED bulbs
 - 14 sets Pinlight 7W LED bulbs
 - Installation/supply of emergency light units are not included.
7. For colors/types of any fixtures or materials to be used on site, consult the end-user and the inspector for approval. Consult the plan and the scope of work for the extent of tasks of the contract. In the event that discrepancies on plans and scope of work occur, generally, the scope of work prevails.
8. *This bid bulletin does not cancel the information given in the scope of work of the issued Bill of Quantities but adds clarification to it. Please attach this added information/bid bulletin to the BOQ and include in the financial envelop.*
9. Resident site engineer is a must for the projects to be undertaken by the contractor of the university. In cases where there are electrical works, it is required that an electrical engineer or a master electrician be a part of contractors' team to supervise all electrical works.
10. In cases of participation to two or more projects, the set of workers and foreman shall be different per project however, the set of engineers and equipment may be reused.

Prepared by:


EFREN R. ROCILLO
 TWG Chair



CENE M. BAGO
 TWG Member


LARRY E. ROCELA
 TWG Member


RONALD P. PEÑA
 TWG Member


ELPIDIO N. RODEROS, JR.
 TWG Member

Approved by:


ENGR. ORLANDO B. DELOS REYES
 Vice Chair, BAC for Infrastructure Projects

Received by the Bidder : _____
 Date : _____