Republic of the Philippines



CAVITE STATE UNIVERSITY

Don Severino de las Alas Campus

Indang, Cavite www.cvsu.edu.ph

BIDS AND AWARDS COMMITTEE

(INFRASTRUCTURE PROJECTS)

SUPPLEMENTAL / BID BULLETIN NO. 2

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents. Please take note of the changes/adjustments for the project, Renovation of Marcos Type Building (HEVTED – West Building) (CvSU-BAC-INFRA-22-008) with an ABC of ₱ 6,796,972.28:

1. Site inspection is a must. Verify actual condition of site.

**Site temporary enclosure may be sack or any suitable materials that may enclose the workplace.

2. On earthworks:

- a. All dismantled materials should be piled and hauled to the designated place.
- b. Provide soil poisoning by using environment friendly solution.
- 3. On concrete and masonry/tile works:
 - a. Supply and installation of tiles for the comfort room.
 - b. Job mixing may be allowed but only with the use of concrete mixers.
 - b.1. A concrete strength of 3500 psi or a 1:1.5:3 concrete proportion is to be used.
 - b.2. Fabrication and testing of concrete samples shall be done by the contractor. Sample test results shall be attached to the billing.
 - c. Existing roof beams and columns shall be retained. New roof beams shall be installed and columns shall be extended to attain the height shown in the plan.
 - d. Non-load bearing CHB shall be used to extend existing walls and partitions.
- On carpentry and miscellaneous work:
 - Any commercially available pre-painted ceiling spandrel shall be provided including ceiling spandrel with holes for ventilation
 - b. Any commercially available decorative wood molding may be used.
 - Note: Choices on commercially available materials need the approval of inspector/university.
 - c. Steel doors are not fire rated but pre-painted and 8 units must be supplied and installed complete with all heavy-duty accessories.
 - Existing glass doors are to be replaced.
 - e. See plan for the location of all doors and windows to be supplied and installed.
- 5. On trusses and roofing:
 - a. Supply and installation of a new set of trusses and roofing.
 - b. Anchor bolts to be used shall be 4-16mm Ø x 200mm (see additional plan) on 12mm thick base plate.
- 6. On plumbing works:
 - a. All works about plumbing (water supply, sewer line, downspout and open canal) will be based on the existing design and actual condition/location on site.
 - b. Disposal of sewer line is to the nearest existing drainage.
 - c. Tap the water supply to the nearest source.
 - d. Provide gate valves for each CR and water meter to the whole water system.
- 7. On painting works:
 - a. The whole building shall be painted including grills.
- For colors/types of any fixtures or materials to be used on site, consult the end-user and the
 inspector for approval. Consult the plan and the scope of work for the extent of tasks of the
 contract. In the event that discrepancies on plans and scope of work occur, generally, the scope
 of work prevails.

- 9. This bid bulletin does not cancel the information given in the scope of work of the issued Bill of Quantities but adds clarification to it. Please attach this added information/bid bulletin to the BOQ and include in the financial envelop.
- 10. Resident site engineer is a must for the projects to be undertaken by the contractor of the university. In cases where there are electrical works, it is required that an electrical engineer or a master electrician be a part of contractors' team to supervise all electrical works.
- 11. In cases of participation to two or more projects, the set of workers and foreman shall be different per project however, the set of engineers and equipment may be reused.

Prepared by:		
EFREN R. ROCILLO TWG Chair	CENEM BAGO TWG Member	LARRY E. ROCELA TWG Member
RONALD P. PEÑA TWG Member	ELPIDIO N. RODEROS, JR. TWG Member	
Approved by:		
ENGR ORLANDO B. DELOS Vice Chair, BAC for Infrastruc	S REYES ture Projects	
Received by the Bidder :		