



Republic of the Philippines
CAVITE STATE UNIVERSITY
Don Severino de las Alas Campus
Indang, Cavite
www.cvsu.edu.ph

BIDS AND AWARDS COMMITTEE
(INFRASTRUCTURE PROJECTS)

BID BULLETIN NO. 2

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents. Please take note of the changes/adjustments for the project, **Completion of Administration Building at Carmona Campus (CvSU-BAC-INFRA-23-023)** with an ABC of ₱ 7,464,665.58.

1. Site inspection is a must. Verify actual condition of site.
 - Site temporary enclosure may be sack or any suitable materials that may enclose the workplace.
2. In electrical works, take note of the revised electrical plan (E-5 to E-8).
3. In miscellaneous works, all doors for installation except for aluminum doors and CR doors must be steel panel door with glass view window and steel flush door.
4. Supply and installation of stainless gutter and flushing and pre-painted fascia cover, all 0.6 mm thick.

GENERAL NOTES:

1. The colors, types and specifications of all fixtures and materials to be used on site should be consulted to the inspector or end-user for approval. As possible, let the end-user or the inspector sign the approved sample. Consult the plan and the scope of work for the extent of tasks of the contract.
2. In the event that discrepancies on plans and scope of work occur, generally, the scope of work prevails. Further, whichever is advantageous to the government is given priority.
3. *This bid bulletin does not cancel the information given in the scope of work of the Bill of Quantities but adds clarification to it. Please attach this added information/ bid bulletin to the BOQ and include in the financial envelope.*

Prepared by:


EFREN R. ROCILLO
TWG Chair



CENE M. BAGO
TWG Member


LARRY E. ROCELA
TWG Member


RONALD P. PEÑA
TWG Member


ELPIDIO N. RODEROS, JR.
TWG Member

Approved by:


MA. AGNES P. NUESTRO, Ph.D.
Chair, BAC for Infrastructure Projects

Received by the Bidder : _____
Date : _____