



Republic of the Philippines  
**CAVITE STATE UNIVERSITY**  
Don Severino de las Alas Campus  
Indang, Cavite  
www.cvsu.edu.ph

**BIDS AND AWARDS COMMITTEE**  
(INFRASTRUCTURE PROJECTS)

**SUPPLEMENTAL / BID BULLETIN NO. 1**

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents. Please take note of the changes/adjustments for the project, **Construction of Parking Space and Electrical Feeder Line for Bahay Alumni (CvsU-BAC-INFRA-24-002)** with an ABC of ₱ 1,406,479.46:

1. Site inspection is a must. Verify actual condition of site.
2. Site temporary enclosure may be sack or any suitable materials that may enclose the workplace.
3. There is an additional plan on electrical (feeder line) to increase detailing.
4. Provide clearing of the area for parking.
5. For Item IV. Concrete Pavement
  - a. Provide necessary formworks to complete the works.
  - b. Parking space shall be 0.15 meters thick; 23 meters long and 10.10 meters wide (see plan).
  - c. Use ready mixed concrete with 3500 psi strength @ 28 days.
  - d. Provide 10 mm 0 deformed bar for reinforcement spaced at 0.40 meters bothways.
  - e. See plans/consult the end user and project inspector for further extent of works.
6. Item V Miscellaneous Works include the electrical works and the chipping/retouching/repainting works of the area affected by the installation of conduit pipe raceway up to the wall of existing Gymnasium building.
7. The issued plan of ramps for the alumni building may be disregarded since that is not part of the scope of this project.

**GENERAL NOTES:**

1. *This bid bulletin does not cancel the information given in the scope of work of the Bill of Quantities (BOQ) but adds clarification to it. Please attach this added information/bid bulletin to the BOQ and include in the financial envelop (envelop 2).*
2. The colors, types and specifications of all fixtures and materials to be used on site should be consulted to the inspector or end-user for approval. As possible, let the end-user or the inspector sign the approved sample. Further, consult the plan and the scope of work for the extent of tasks of the contract.
3. In the event that discrepancies on plans and scope of work occurs, generally, the scope of works prevails. Further, whichever is advantageous to the government is given priority.
4. For concrete works: provide ready mixed concrete of specified strength.
5. Materials to be used on site must be subjected to material testing which will be charged to the contractor.
6. Let it be observed that all door knobs to be installed on doors of all buildings be that of heavy-duty lever type.
7. Multi-roles are allowed for the key personnel who are the engineers and managers of the project.



Republic of the Philippines  
**CAVITE STATE UNIVERSITY**  
Don Severino de las Alas Campus  
Indang, Cavite  
www.cvsu.edu.ph

8. All certifications and pertinent documents on electrical works shall be signed and sealed by PEE. In addition, electrical permits shall be up to securing approved CFEI.

Prepared by:

**EFREN R. ROCILLO**  
TWG Chair

**CENE M. BAGO**  
TWG Member

**LARRY E. ROCELA**  
TWG Member

**RONALD P. PEÑA**  
TWG Member

**ELPIDIO N. RODEROS, JR.**  
TWG Member

**TRISHA MARIE I. JULIANO**  
TWG Member

**RYAN JANSSEN R. SANCHEZ**  
TWG Member

Approved by:

**MA. AGNES P. NUESTRO, Ph.D.**  
Chair, BAC for Infrastructure Projects

Received by the Bidder : \_\_\_\_\_  
Date : \_\_\_\_\_