



Republic of the Philippines
CAVITE STATE UNIVERSITY
Don Severino de las Alas Campus
Indang, Cavite
www.cvsu.edu.ph

BIDS AND AWARDS COMMITTEE
(INFRASTRUCTURE PROJECTS)

SUPPLEMENTAL / BID BULLETIN NO. 2

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents. Please take note of the changes/adjustments for the project, **Completion of Five-Storey CEMDS Building (CvSU-BAC-INFRA-25-009)** with an **ABC of ₱ 5,000,000.00.**

1. Site inspection is a must. Verify actual condition of site.
2. Site temporary enclosure may be sack or any suitable materials that may enclose the workplace.
3. See Bid Bulletin Plan 01 for details of Mechanical and Fire Protection Works
4. See Bid Bulletin Plan 02 for details of Plumbing Works
5. For details of Carpentry Works, specifically the Ceiling Works, see Item IV.B.
6. For details of Miscellaneous Works, See Plan A-7 for details of doors and windows
7. For details of Fire Escape and Ladder, see Bid Bulletin Plan 03
8. For items including the mobilization, demobilization and processing of permits, required to provide a detailed breakdown of costs. These items should not be presented as lump sum amounts, but rather as itemized cost components
9. Detailed Cost Estimate will be provided by the contractor using their own format.
10. Registered Electrical Engineer (REE) is required for the supervision of the work, and a Professional Electrical Engineer (PEE) is required for the signing and sealing of the test results for electrical components, as well as the Final Electrical Inspection Report (with notary public) to be submitted during the Final Billing. The PEE may be a consultant; a notarized contract should be included in the bid to be submitted.

GENERAL NOTES:

1. *This bid bulletin does not cancel the information given in the scope of work of the Bill of Quantities (BOQ) but adds clarification to it. Please attach this added information/bid bulletin to the BOQ and include in the financial envelope (envelope 2).*
2. *The colors, types and specifications of all fixtures and materials to be used on site should be consulted to the inspector or end-user for approval. As possible, let the end-user or the inspector sign the approved sample. Further, consult the plan and the scope of works as well as the end-user and inspector for the extent of tasks of the contract.*
3. *In the event that discrepancies on plans and scope of work occurs, generally, the scope of works prevails. Further, whichever is advantageous to the government is given priority.*
4. *For concrete works: provide ready mixed concrete of specified strength.*
5. *Materials to be used on site must be subjected to material testing which will be charged to the contractor.*
6. *Let it be observed that all door knobs to be installed on doors of all buildings be that of heavy-duty lever type.*
7. *Multi-roles are allowed for the key personnel who are the engineers and managers of the project.*
8. *All certifications and pertinent documents on electrical works shall be signed and sealed by PEE. In addition, electrical permits shall be up to securing approved CFEI.*
9. *Location of temporary warehouse and barracks will be discussed during the pre-construction meeting.*



Republic of the Philippines
CAVITE STATE UNIVERSITY
Don Severino de las Alas Campus
Indang, Cavite
www.cvsu.edu.ph

10. *All pages of the bidding documents should be originally signed by the authorized signatory (Original, Copy 1 and Copy 2). The use of the Certified True Copy stamp is not required.*
12. *Use readable font size on the detailed estimate.*


Prepared by:



MICHELLE A. SANTOS
BAC Secretary



EFREN R. ROCILLO
TWG Chair


CENE M. BAGO
TWG Member


LARRY E. ROCELA
TWG Member


RONALD P. PEÑA
TWG Member


ELPIDIO N. RODEROS, JR.
TWG Member


TRISHA MARIE I. JULIANO
TWG Member


RYAN JANSSEN R. SANCHEZ
TWG Member

Approved by:


MELBOURNE R. TALACTAC, PhD
Chair, BAC for Infrastructure Projects

Received by the Bidder : _____
Date : _____